

# Emission Test Certificate

Thursday April 16<sup>th</sup>, 2020

Supplier: TITUS TEKFORM Pty Ltd (8/59 Jersey Road, Bayswater, VIC, 3153, Australia)

Sample Description: Titus – Riven Walnut 602.8W24.120.030

Date Tested: March 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

**Emission Data (24 hrs exposure):**

<p align="center"><b>Green Building Council of Australia</b> Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center"><b>Titus – Riven Walnut</b> <b>602.8W24.120.030</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.037 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate limit: ≤ 0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: 0.251 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

V2003062